

**NON-CONFIDENTIAL**

---

1 **Request IR-1:**

2

3 **With respect to Section 3 of Exhibit M2:**

4

5 **The proposed Maritime Link will consist of a hybrid arrangement of overhead and**  
6 **underground dc transmission which is connected to ac transmission at both ends. Ideally,**  
7 **high speed clearing of overhead line faults and rapid restart of the dc link would be**  
8 **desirable. However, fast fault suppression capability and high speed dc breakers are new**  
9 **and evolving technology for VSC HVDC.**

10

11 **(a) Please provide all stability and reliability studies carried out to determine the**  
12 **acceptability of clearing dc line faults with dc breakers and ac breakers, and slow**  
13 **restart with VSC-based HVDC.**

14

15 **(b) Also, please indicate how slow is considered acceptable when compared with**  
16 **LCC-based HVDC in which dc line faults are cleared rapidly and HVDC restarted**  
17 **without mechanical breakers.**

18

19 **Response IR-1:**

20

21 High-speed clearing is not a requirement for the Maritime Link. Clearing of DC faults is by  
22 tripping the AC circuit breakers. In Newfoundland, the LIL controller responds to the rising  
23 frequency and ramps the import back. Operators then decide whether to re-instate and re-ramp  
24 the link within 10 minutes or commit reserves within Nova Scotia and the Maritime Area to  
25 make up the loss on the Eastern Interconnection.

26

27 **(a-b) High-speed clearing is not required and will not be employed. Studies concerning speed**  
28 **requirements are therefore not relevant.**

**NON-CONFIDENTIAL**

---

1 **Request IR-2:**

2  
3 **With respect to Section 3 and 4 of Exhibit M2:**

4  
5 **(a) Please provide brief technical and cost information obtained from Vendors for**  
6 **VSC-based HVDC.**

7  
8 **(b) Please clarify whether the vendor information is for a system with dc line fault**  
9 **suppression and rapid restart (without mechanical breakers) for hybrid OH and**  
10 **cable transmission.**

11  
12 **Response IR-2:**

13  
14 **(a) Please refer to CA/SBA IR-147 and CA/SBA IR-148.**

15  
16 Early indicative cost estimates were secured from converter vendors to facilitate  
17 comparisons of LCC and VSC technology, through a process of consultation. The  
18 standalone cost of LCC is lower than VSC without the system upgrades LCC requires.  
19 Based on an evaluation of system development costs under each option, a decision was  
20 made to pursue only the VSC option. The decision is based upon the factors required to  
21 attain a cost-effective technical solution.

22  
23 Subsequent design development at the conceptual and functional design stage included  
24 development of functional requirements for the VSC installations, and design of electrical  
25 interconnection requirements and civil/structural site development. This led to the  
26 preparation of the mini-spec included in Hingorani IR-10, which was issued to vendors  
27 for budget pricing. A summary of the budget pricing received from vendors is provided  
28 in Hingorani IR-10.

29  
30 **(b) The mini-spec did not include provision for dc fault suppression and rapid restart.**

---

**NON-CONFIDENTIAL**

---

1 **Request IR-3:**

2

3 **With respect to Section 3 and 4 of Exhibit M2:**

4

5 **(a) Please provide technical and cost information obtained from Vendors for LCC-**  
6 **based HVDC.**

7

8 **(b) Please clarify whether this vendor information is for a system with dc line fault**  
9 **suppression and rapid restart (without mechanical breakers) for hybrid OH and**  
10 **cable transmission.**

11

12 **Response IR-3:**

13

14 **(a) Please refer to UARB IR-2.**

15

16 During the conceptual and functional design stage, further definition was prepared for the  
17 functionality of the converters, along with preliminary design of the electrical  
18 interconnections and the civil/structural works at the converter stations. Based on this  
19 work, the mini-spec was prepared for VSC technology only (provided in  
20 Hingorani IR-10) and issued to vendors for budget pricing. At this stage, the converter  
21 prices for VSC technology were found to be somewhat higher than the indicative pricing  
22 secured during vendor consultations (pricing information provided in Hingorani IR-10).

23

24 **(b) For the Maritime Link there is no requirement for rapid restart.**

**NON-CONFIDENTIAL**

---

1 **Request IR-4:**

2  
3 **With respect to Section 3 of Exhibit M2:**

4  
5 **To reduce the exposure to frequent faults on the overhead dc line,**

6  
7 **(a) Was any consideration given to a cable sea entry point near Bottom Brook so that a**  
8 **VSC-based HVDC with no overhead line in Newfoundland would result?**

9  
10 **(b) Alternatively, was an underground cable from Bottom Brook to Cape Ray or**  
11 **relocating the converter station to Cape Ray considered?**

12  
13 **(c) Were similar routing alternatives to minimize the amount of overhead line in Nova**  
14 **Scotia to Woodbine (i.e. cable landing site closer to Woodbine or greater use of**  
15 **underground cable) considered?**

16  
17 **(d) Please provide information from Vendors on any all-cable based VSC-based**  
18 **alternatives (with no overhead dc line) provided.**

19  
20 **Response IR-4:**

21  
22 **(a) Yes, an alternate landing further along the west coast was considered. Due to the cost of**  
23 **cabling, it was screened out as an option.**

24  
25 **(b) Due to the high cost of underground cable, plus the number of river crossings along the**  
26 **route, the underground option was eliminated. Relocation of the converter to Cape Ray**  
27 **was considered, and was dismissed due to the higher cost of AC transmission**  
28 **construction from Bottom Brook to Cape Ray.**

Maritime Link Project (NSUARB ML-2013-01)  
NSPML Responses to UARB - Hingorani Information Requests

**NON-CONFIDENTIAL**

---

- 1 (c) Yes, initial development considered a converter station at Langan. This was abandoned  
2 due to cost and difficulty of crossing TransAtlantic telecommunications cables, 230 kV  
3 GIS substation requirements and system transmission costs.  
4  
5 (d) No vendor pricing was solicited for an all-cable option for the reasons noted above.

**NON-CONFIDENTIAL**

---

1 **Request IR-5:**

2

3 **With respect to P41 Line 7-11 of Exhibit M2:**

4

5 **Preamble: Power reversal capability is a disadvantage for LCC Converter based Link**  
6 **because the cable and transformers have to be designed with voltage reversal capability**  
7 **which would be more expensive. VSC does not have polarity reversal. Two way transfer**  
8 **capability therefore costs more than one-way capability particularly for LCC-based**  
9 **technology.**

10

11 **Please provide information on the value of Power Reversal capability.**

12

13 Response IR-5:

14

15 The Maritime Link is being designed for use of VSC technology, and the cost premiums  
16 applicable to LCC technology for power reversal are not applicable for voltage source  
17 converters. The systems on both ends of the Maritime Link are being upgraded initially to  
18 accommodate the 500 MW forward flow from Newfoundland to Nova Scotia. With these  
19 upgrades in place, system studies have indicated that reverse power flow of 100-250 MW can be  
20 accommodated subject to transmission system conditions, and NSPML does not plan to make  
21 any investments in system upgrades to facilitate expansion of these reverse flow limits.

22

23 The value of power reversal capability principally accrues to Nalcor, in low-probability  
24 contingency events involving loss of both poles of the Labrador-Island Link. Under such  
25 circumstances, it may be possible for Nova Scotia to provide emergency support for the resulting  
26 capacity shortage in Newfoundland.

**NON-CONFIDENTIAL**

---

1 **Request IR-6:**

2

3 **With respect to P43 Line 8-15 of Exhibit M2:**

4

5 (a) **Please provide information on the approximate AC Effective Short-Circuit Capacity**  
6 **at each converter connection point.**

7

8 (b) **How much additional dynamic reactive power would be needed for LCC option?**

9

10 Response IR-6:

11

12 (a) At the Woodbine 345 kV terminal, the minimum short-circuit capacity with transmission  
13 normal conditions is 1900 MVA. The effective short -circuit capacity will be just below  
14 1900 MVA. At Bottom Brook the minimum short-circuit ratio with transmission normal  
15 conditions is just below 900 MVA. All reactive support will be provided by the VSC with  
16 the exception of any low capacity high-frequency filter included with the converter.

17

18 (b) At Woodbine 345 kV, the LCC itself requires approximately 300 MVA<sub>r</sub>. Options to  
19 provide this include shunt capacitors and filters and converting Ligan units for  
20 synchronous condenser operation. At Bottom Brook, in addition to the reactive power  
21 required to supply the converter, there is also a requirement to supply dynamic reactive  
22 support to the 230 kV system on contingency (contingency reserves) of over 200 MVA<sub>r</sub>.  
23 These factors considered Bottom Brook is not considered a viable terminal for a  
24 conventional LCC converter alone.

**NON-CONFIDENTIAL**

---

1 **Request IR-7:**

2

3 **With respect to Section 3 of Exhibit M2:**

4

5 **Please provide information obtained from Vendors on dc breakers and high speed clearing**  
6 **of dc line faults for VSC-based HVDC with OH or Hybrid OH-Cable line.**

7

8 Response IR-7:

9

10 As indicated in Hingorani IR-1, high-speed clearing for dc faults is not a requirement. Faults are  
11 cleared by the AC circuit breaker. During the final design, any requirements for default clearing  
12 will be assessed with vendors. NSPML is aware of the industry developments in this area.



**NON-CONFIDENTIAL**

---

1 **Request IR-8:**

2

3 **With respect to Section 3 of Exhibit M2:**

4

5 **Preamble: LCC would have lower losses compared to VSC.**

6

7 **Please provide information on the value of losses for NSPI and value given to Vendors**  
8 **for procurement purposes.**

9

10 Response IR-8:

11

12 The request for proposals (RFP) from vendors is currently being assembled and therefore cannot  
13 be provided at this time. The value of losses are being finalized and will be included in the  
14 comparison of proposals. The converter losses for the VSC is higher than LCC with the extent  
15 depending on the technology. Current VSC technologies can achieve losses at rated load which  
16 are an additional 0.2 percent more than the LCC technology.

**NON-CONFIDENTIAL**

---

1 **Request IR-9:**

2

3 **With respect to P41 Line 1-6 of Exhibit M2:**

4

5 **Please provide information on the estimated losses which would be deducted from NSPI**  
6 **share of 170 MW.**

7

8 Response IR-9:

9

10 Please refer to footnote 17 on Page 33 of the Application, and to NSUARB IR-13.

**CONFIDENTIAL (attachments only)**

---

1 **Request IR-10:**

2

3 **With respect to P40 line 11-18 of Exhibit M2:**

4

5 **Please provide:**

6

7 **(a) Information on preliminary Technical Specifications shown to HVDC Converter**  
8 **Vendors (ABB, Siemens, Alstom)**

9

10 **(b) Please provide technical and cost information from Vendors for both VSC and LCC**  
11 **options.**

12

13 **Response IR-10:**

14

15 **(a) Please refer to Confidential Attachment 1.**

16

17 **(b) Please refer to Confidential Attachment 2. Cost information on an LCC option was not**  
18 **requested.**

**UARB-Hingorani IR-10 Attachment 1 has been removed  
due to confidentiality.**

**UARB-Hingorani IR-10 Attachment 2 has been removed  
due to confidentiality.**

**NON-CONFIDENTIAL**

---

1 **Request IR-11:**

2

3 **With respect to Section 3 of Exhibit M2:**

4

5 **Preamble: VSC Converters do not have significant overload capability. For loss of one**  
6 **pole, LCC-based HVDC converters can provide 33% overload, for very small additional**  
7 **cost and even 100% overload for reasonable time with modest extra cost.**

8

9 **Please provide information on overload capability needed for loss of one pole, including**  
10 **information from Vendors on overload capability of their VSC and LCC converters.**

11

12 Response IR-11:

13

14 No additional overload capability is required. Depending on ML loading at the time of a pole  
15 outage, the remaining pole is available to ramp to its full 250 MW rating on the sending end.  
16 Any shortfalls realized at that time can be met in the short term via system interconnections and  
17 in the longer term through generation redispatch or suspension of exports.

**NON-CONFIDENTIAL**

---

1 **Request IR-12:**

2

3 **With respect to Figure 4-1, page 76 of Exhibit M2:**

4

5 **Please provide information on how the cost of \$450 M for converters was derived including**  
6 **information from Vendors or other prior projects.**

7

8 Response IR-12:

9

10 The \$450 M covers the cost of the work scope associated with the two converters. It includes all  
11 infrastructure related to the integration of the two converters, which includes: site preparation,  
12 converter equipment, substations, grounding systems, buildings, site protection, storage facilities.  
13 For the converter stations alone, a “mini-specification” was developed to provide high-level  
14 functional specifications for the converters, which was sent to three international vendors for  
15 budget quotations. In parallel with this vendor pricing, the project engineering consultants  
16 prepared an independent estimate based on past projects implemented using VSC technology.  
17 The base EPC cost for the converter island was chosen based on consideration of the three  
18 vendor prices and the consultant’s estimate.

19

20 The balance of the converter cost category was estimated by the engineering consultant, based on  
21 completed engineering, vendor equipment price quotations and construction cost quotations. The  
22 design development for the balance of plant was consistent with a DG2 level plan, where plan  
23 drawings and layouts were developed to facilitate preparation of bills of materials and  
24 construction quantities that were used to solicit vendor and contractor estimates. All estimates  
25 included appropriate contingency based on the level of uncertainty at the conclusion of the  
26 design development.

**NON-CONFIDENTIAL**

---

1 **Request IR-13:**

2

3 **With respect to Section 3 of Exhibit M2:**

4

5 **Was VSC-based HVDC with all cable transmission considered as a competitive**  
6 **procurement option and if not please explain why not?**

7

8 Response IR-13:

9

10 Please refer to NSUARB IR-39.



**NON-CONFIDENTIAL**

---

1 **Request IR-14:**

2

3 **With respect to Section 3 of Exhibit M2:**

4

5 **Was LCC-based HVDC with needed reactive power and filters considered for competitive**  
6 **procurement option and if not please explain why not?**

7

8 Response IR-14:

9

10 Please refer to Hingorani IR-6 and Hingorani IR-4.

11

12 In the initial planning stage, indicative cost estimates were secured from LCC and VSC vendors,  
13 and system studies were undertaken to identify system requirements for integration of both LCC  
14 and VSC technology into the system. These studies identified requirements under the LCC  
15 scenario for dynamic VAr support in Cape Breton (not needed in the VSC scenario), additional  
16 dynamic VAr support in Newfoundland, and a prospective requirement to relocate the Bottom  
17 Brook converter. Considering the capital costs for the alternative converter technologies, the  
18 capital costs for the corresponding system upgrades, and costs of losses for the two systems, a  
19 decision was made to proceed with VSC technology. LCC pricing was not requested as part of  
20 the “mini-specification” and vendor pricing solicitation.

**NON-CONFIDENTIAL**

---

1 **Request IR-15:**

2

3 **With respect to Section 3.3.3 Exhibit M2:**

4

5 **Please explain what measures will be taken to prevent fish from entering the electrode**  
6 **pond or being attracted to the barrier for the pond.**

7

8 Response IR-15:

9

10 The grounding system will be designed in accordance with all pertinent standards and  
11 regulations, and methods of addressing concerns for aquatic wildlife are well established in  
12 application of shore grounding sites around the world. Details of measures to protect fish and  
13 wildlife are part of the Environmental Assessment process, and the final design of the grounding  
14 site will be consistent with all requirements identified in the EA process.